

Copy of the Fire Safety Certificate issued by Chief Fire Officer, Ahmedabad



AHMEDABAD MUNICIPAL CORPORATION FIRE AND EMERGENCY SERVICES DEPARTMENT

DANAPITH FIRE STATION (HEADQUARTERS), NR.AMC OFFICE, DANAPITH, AHMEDABAD

NOC Number: NOC273617012023

Category: School

NOC Issue Date: 27/02/2023

NO OBJECTION CERTIFICATE

This is to certify that management of M/s **SHIV ASHISH SCHOOL CBSE** located at **STERLING CITY, BOPAL** has installed necessary Fire Protection Equipments mentioned below.

Hydrant System With

- * Main Pump - (1 Nos.)
- * Hose Box with Hose - (5 Nos.)
- * Hydrant Point / Valve - (5 Nos.)
- * Hose Reel - (5 Nos.)

Fire Extinguishers

- * 6 Kg. Capacity ABC Type - (5 Nos.)
- * 4.5 Kg. Capacity Co2 Type - (5 Nos.)

All the Fire Protection Equipments installed shall be maintained in working order throughout the validity period of this certificate.

This Certificate is valid for TWO YEAR from the date of issue.



Ahmedia

(JAYESH N. KHADIA)

Chief Fire Officer (I/c)

Ahmedabad Municipal Corporation

Principals

PRINCIPAL
SHIV ASHISH SCHOOL CBSE
BOPAL, AHMEDABAD

For, SHIV ASHISH FOUNDATION TRUST

Managing Trustee
Managing Trustee / Trustee